



SUPERPURE 10 inch Pleated Sediment Water Filter Replacement Cartridge - 5 Micron

PS10M5



DWT-DS-C-037
Rev 0
Issued 2026-08-24

Replacement filter cartridge

AT A GLANCE

- The folded polyester design packs in far more surface area, so it holds more dirt, lasts longer and keeps water pressure steady.
- The media is washable, which stretches its working life further.
- Best for: Dirtier water, longer life.

SPECIFICATIONS

Micron rating	5 Micron (nominal)
Rated service flow	11 L/min (3 gpm) service per 10" length — scale by format
Operating pressure	Up to 6 bar (600 kPa); fit a pressure regulator where supply pressure exceeds 4.5 bar (450 kPa)
Replacement element & interval	Sediment filter: every 180 days → Same product
Country of origin	China
Warranty	12 months (consumables excluded — see Warranty & support)

FEED WATER

Supply type	Any
-------------	-----

For use on municipal water supplies. Not suitable for untreated borehole, rain or surface water without appropriate pre-treatment and disinfection.

WHAT IT REDUCES

Not designed to reduce: chlorine, chemical contaminants, dissolved solids.

LIMITATIONS & NOTICES

Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system.

The contaminants or other substances removed or reduced by this water filter are not necessarily in all users' water.

Filter life is dependent on actual use and incoming water quality.

Replace the filter cartridge at the required interval, at the rated capacity, or sooner if a noticeable reduction in water flow occurs.

Flush the new cartridge/system as directed before use.

WARRANTY & SUPPORT

12 months from date of purchase. Consumables are excluded: filter cartridges, UV lamps, quartz sleeves and O-rings. The warranty does not cover damage caused by incorrect installation, operation outside the stated limits, water hammer or freezing, missed cartridge replacements, or unauthorised modification or repair.

Specifications are subject to change without notice. While testing was performed under standard laboratory conditions, actual performance may vary with feed water quality, pressure and usage. This document supersedes all previous revisions. E&OE.